


# DATA SHEET

## Battery fuse protection

enwitec article no.	10012808
Customer article no.	
Designation	enwitec BAT BREAKER-Spec.BYD-1xAccu-1xCharger_standard_KS
Application	Battery fuse "BAT BREAKER" for the PV energy storage system with battery charger / inverter
Number and type of battery charger / inverter:	max. 1 Sunny Island except SI 8.0 in off-grid mode
Number and type of energy storage:	max. 1 x BYD B-Box 12.8
General note:	If a different battery charger / inverter is to be used, the suitability of the circuit breaker used (nominal value, tripping characteristic) must be checked by BYD. Cable lugs are not included.

1 x SMA "Single" Sunny Island  
1 x BYD B-Box 12.8

<p>Min. construction distances:</p> <p>Up and down min.: 300 mm</p> <p>Left and right min.: 200 mm</p> <p>forward min.: 800 mm</p> <p>Cable clamping: Must be done on site!</p>
---



Delivery			
Designation	Article no.	Piece	Comments
Cable gland M32x1,5	10011849	4	
Locknut M32x1,5	10000724	4	

